

**HERITAGE MEDCALL
TECHNICAL
SPECIFICATIONS**

**Model HM-561
CARBON MONOXIDE
DETECTOR**

- UL-2075 LISTED
- LOW CURRENT DRAW
- END OF LIFE INDICATOR
- 85 DB TEMPORAL-4 SOUNDER



DESCRIPTION:

UL 2075 listed Carbon Monoxide (CO) alarm approved for system use and meets testing requirements of UL 2034 listing. End of Sensor life indicator warns when alarm replacement is needed. Test / Silence button. LED / Sounder - status indicator.

SPECIFICATIONS:

Operating Temp.....: 40° TO 100°F
 Sounder.....85db
 Power.....12VDC
 Current
 Normal.....8ma normal
 Alarm.....75ma alarm
 Relay Contact.....NO/NC
 CO alarm level.....70 ppm/60-240 minutes

DIMENSIONS:

Width.....2.7" (6.9 cm)
 Length.....6" (15.2 cm)
 Depth.....1.4" (3.6 cm)

INDICATORS:

LED	Sounder	Status
Green	Off	Safe Air
Red	4 rapid beeps every 5 seconds.	Alarm
Flashing Amber every 30 – 60 sec.	Chirp follows each LED flash.	Trouble
Flashing Green every 1 – 2 Sec	Chirps every 5 minutes.	End of Life Sensor.

INSTALLATION:

Direct wall mountable using wall anchors. 18 – 22 gauge wire.

TESTING:

Press and hold Test / Hush button for CO test. Sounder will beep 4 times, pause 5 seconds, beep 4 times and LED will turn green to indicate proper CO operation and relay will trip and reset after 9 seconds.